

## **Smoke Alarm & Carbon Monoxide Alarm Requirements Residential Multiple Dwellings:**

For existing dwellings, including those with alterations or repairs under the Codes of New York State, Section 704.2, .3, .4.

Smoke Alarms are required in ALL units.

1. On the ceiling or wall outside of each separate sleeping area in the immediate vicinity of bedrooms.
2. In each room used for sleeping purposes.
3. In each floor level within a dwelling unit, including basements and cellars.

Carbon Monoxide Alarms are required as per Section 1225.2 in ALL units.

1. The lowest floor levels of the home, basements and first floors, all common areas of floors with bedrooms.



## **Requisitos De Alarmas De Humo Y Alarmas De Monóxido De Carbono Viviendas Múltiples De Residencia:**

Para viviendas existentes incluyendo viviendas con alteraciones y reparaciones por orden de los Códigos Del Estado de Nueva York, Sección 704.2, .3, .4.

Alarmas de Humo son requeridas en CADA vivienda.

1. En el techo o pared de el área más cercana a cada dormitorio.
2. En cada cuarto que es usado para el propósito de dormir, (dormitorios).
3. En cada nivel de la casa dentro de la vivienda incluyendo los sótanos.

Alarmas de Monóxido de Carbono son requeridas por Sección 1225.2,  
en CADA vivienda.

1. En el nivel de la casa mas bajo de la vivienda, incluyendo los sótanos, y el primer nivel de la casa, y todas las área en común en niveles con dormitorios.